



rfo-sfps-ahd@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOAHM/2025/00105434

Date: 05/02/2025

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOAHM/2025/00105434/R1

Building Occupancy/Category: Educational (non-residential)

To,

VYAS SHRIKANT DEVIPRASAD
- OPP. VRAJ GARDEN SHELA- BOPAL sanand SANAND Ahmedabad 382110
Fire Region: Ahmedabad RFO
Mobile No: 9687642843 Email ID: shrikantvyas84@gmail.com

This has reference to your Application No.2025/00107607 dated 03/02/2025 for Fire Safety Certificate Renewal (FSCR) for the building/premise SHANTI ASIATIC SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: 253,1253/P1
4. Village Name: sanand
5. Name of Block(s): SHANTI ASIATIC SCHOOL

The building/premise was inspected on 05/02/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 05/02/2025
2. Six monthly inspection was done on 05/02/2025

The Fire Safety Certificate is renewed for a period of two (2) years upto 05/02/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Jigarkumar Rankalbhai Patel
Fire Safety Officer - General (FSCO-G)
2021/000654

Date: 05/02/2025
Time: 09:47 AM

SHANTI ASIATIC SCHOOL

PRINCIPAL
(SR. SCHOOL)

FSCA/O/RFOAHM/2025/00105434/R1

This is a digitally verified certificate, hence doesn't require physical signature. To verify the authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.